

## Auxiliary Power Module

Information Leaflet I.L. 5721B39H03

Effective May 2011  
New Information



**FIGURE 1. AUXILIARY POWER MODULE**

### Overview

Eaton's Auxiliary Power Module (See **Figure 1**) is an intermittent duty device specifically used to power up the Digitrip™ family of trip units. This permits easy bench testing and field testing of the trip units as well as displaying data, settings and the initial configuring of communication address and baud rates. Additionally, the module will power an OPTIMizer™ handheld programmer.

The Auxiliary Power Module catalog number is **PRTBAPMDV**. (See **Figure 2**) This device permits an input voltage from 100VAC to 240VAC. The output is a regulated DC voltage (nominally 32VDC) when loaded into a Digitrip circuit. The output cable is six feet (1.8m) in length with a keyed output connector. (See **Figure 3**)

In general, when the connector is inserted into the aux power port of the Digitrip product, the status LED should flash, with a one second repetition rate, confirming the trip unit is powered up.

**NOTE:** The end user must supply an appropriate adaptor to convert the device for international use.

### CAUTION

**OBSERVE ALL RECOMMENDATIONS, NOTES, CAUTIONS, AND WARNINGS RELATING TO THE SAFETY OF PERSONNEL AND EQUIPMENT. OBSERVE AND COMPLY WITH ALL GENERAL AND LOCAL HEALTH AND SAFETY LAWS, CODES, AND PROCEDURES.**

**WARNING**

**ONLY CERTIFIED AND COMPETENT PERSONNEL SHOULD ATTEMPT TO INSTALL OR MAINTAIN POTENTIALLY HAZARDOUS EQUIPMENT.**

**DO NOT ATTEMPT TO INSTALL OR PERFORM MAINTENANCE ON EQUIPMENT WHILE IT IS ENERGIZED. DEATH OR SEVERE PERSONAL INJURY CAN RESULT FROM CONTACT WITH ENERGIZED EQUIPMENT. ALWAYS VERIFY THAT NO VOLTAGE IS PRESENT BEFORE PROCEEDING. ALWAYS FOLLOW SAFETY PROCEDURES.**


**EATON IS NOT LIABLE FOR THE MISAPPLICATION OR MISINSTALLATION OF ITS PRODUCTS.**



**FIGURE 2. AUXILIARY POWER MODULE MARKING**

Digitrip™ and OPTIMizer™ are trademarks of Eaton Corporation.

Eaton Corp.  
1000 Cherrington Parkway  
Moon Township, PA 15108-4312  
United States  
Telephone: 1-800-525-2000  
www.Eaton.com



**FIGURE 3. POLARITY OF CONNECTOR**

### **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITY**

The information recommendations, descriptions and safety notations in this document are based on Eaton's experience and judgment and may not cover all contingencies. If further information is required an Eaton sales office should be consulted.

Sale of the product shown in this literature is subject to the terms and conditions outlined in appropriate Eaton Electrical Inc. selling policies or other contractual agreement between Eaton and the purchaser.

THERE ARE NO UNDERSTANDINGS, AGREEMENTS, WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING WARRANTIES OF FITNESS FOR A PARTICULAR PURPOSE OR MERCHANTABILITY, OTHER THAN THOSE SPECIFICALLY SET OUT IN ANY EXISTING CONTRACT BETWEEN THE PARTIES. ANY SUCH CONTRACT STATES THE ENTIRE OBLIGATION OF EATON ELECTRICAL INC. THE CONTENTS OF THIS DOCUMENT SHALL NOT BECOME PART OF OR MODIFY ANY CONTRACT BETWEEN THE PARTIES.

**IN NO EVENT WILL EATON ELECTRICAL INC. BE RESPONSIBLE TO THE PURCHASER OR USER IN CONTRACT, IN TORT (INCLUDING NEGLIGENCE), STRICT LIABILITY OR OTHERWISE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGE OR LOSS WHATSOEVER, INCLUDING BUT NOT LIMITED TO DAMAGE TO OR LOSS OF USE OF EQUIPMENT, PLANT OR POWER SYSTEM, LOSS OF PROFITS OR REVENUES, OR CLAIMS AGAINST THE PURCHASER OR USER BY ITS CUSTOMERS RESULTING FROM THE USE OF THE PRODUCTS OR INFORMATION, RECOMMENDATIONS AND DESCRIPTIONS CONTAINED HEREIN.**

© 2011 Eaton Corporation  
All Rights Reserved  
Printed in USA  
Publication No. I.L. 5721B39